

## **GENERAL REQUIREMENTS FOR DISPLAY AND SALES OF FIREWORKS**

- **NO SALE OF FIREWORKS IS ALLOWED UNTIL A FIRE INSPECTION IS CONDUCTED AND A PERMIT FOR SALE IS ISSUED BY A FIRE PREVENTION OFFICER.**
- Every CFRS facility and store shall have no fewer than two portable fire extinguishers with a minimum range of 2A, least one of which shall be of the pressurized water type.
- Smoking shall not be permitted inside or within 50ft. of the Consumer Fireworks Stand area.
- At least one sign that reads as follows, in letters at least 2 in. (51 mm) high on **contrasting** background shall be conspicuously posted at each entrance or within **10 ft.** (3.05) of every aisle directing serving the CFRS area in a store: **FIREWORKS – NO SMOKING**
- No open flame devices. Electrical heaters must be at a safe distance from fireworks. (3 feet)
- Fireworks stands and tents must have at least 8 ft. clearance from overhead power line with 600 volts or less (NFPA 70 Article 225) and a distance of 12.5 ft. from overhead power lines greater than 600 volts (NFPA 70 Article 225) and LAC55:103.
- In stores that sell fireworks, display must be at least 10 ft. from the exit. Fireworks shall not be displayed where the sun will shine through the glass onto the fireworks.
- Fireworks cannot be sold from automotive vehicles. No fireworks shall be stored or sold within 75 ft. of physical facility where flammables or combustibles stored, sold or used. (R.S. 51:653.B)
- No fireworks other than Class “C” (common or UN0336) shall be sold. (R.S.51:653.A)
- Fireworks stand is at least 25 feet from public street or highway (R.S. 51:653.G) Stand is at least 50 feet from flammable liquid dispenser (such a gasoline pumps) or flammable vapors. (Vent pipes from gas storage tanks). (R.S. 51:653.D)
- Tent must be fire retardant(R.S. 40:1613)
- No motor vehicle or trailer used for the storage of consumer fireworks shall be parked within 10 ft. of a CFRS facility.
- No motor vehicle parking shall be within **10 ft.** of firework stands or tents.